



### Anteile "aktives" Chlor in Abhängigkeit vom pH-Wert

pH	%HOCl (20 °C)	pH	%HOCl (20 °C)
4	99.97	8	25.309
4.1	99.963	8.1	21.207
4.2	99.953	8.2	17.614
4.3	99.941	8.3	14.517
4.4	99.926	8.4	11.886
4.5	99.907	8.5	9.678
4.6	99.883	8.6	7.844
4.7	99.852	8.7	6.333
4.8	99.814	8.8	5.097
4.9	99.766	8.9	4.091
5	99.706	9	3.277
5.1	99.63	9.1	2.621
5.2	99.534	9.2	2.093
5.3	99.415	9.3	1.67
5.4	99.264	9.4	1.331
5.5	99.075	9.5	1.06
5.6	98.839	9.6	0.844
5.7	98.542	9.7	0.672
5.8	98.172	9.8	0.534
5.9	97.709	9.9	0.425
6	97.133	10	0.338
6.1	96.418	10.1	0.268
6.2	95.532	10.2	0.213
6.3	94.439	10.3	0.17
6.4	93.099	10.4	0.135
6.5	91.464	10.5	0.107
6.6	89.486	10.6	0.085
6.7	87.115	10.7	0.068
6.8	84.302	10.8	0.054
6.9	81.01	10.9	0.043
7	77.213	11	0.034
7.1	72.911	11.1	0.027
7.2	68.132	11.2	0.021
7.3	62.939	11.3	0.017
7.4	57.428	11.4	0.013
7.5	51.726	11.5	0.011
7.6	45.979	11.6	9e-03
7.7	40.337	11.7	7e-03
7.8	34.94	11.8	5e-03
7.9	29.902	11.9	4e-03